

EMBASSY OF THE UNITED STATES OF AMERICA
REQUEST FOR QUOTATION N. 19H08023Q0019
TESTING FUEL FOR PERMANENT TANKS AT NEC
QUESTIONS AND ANSWERS

The following questions were presented prior the Site Visit:

Q 1. Is any PPE (Personal Protective Equipment) required to be provided by the Prospective Contractor or is the US Embassy going to provide it? If required to be provided by the Prospective Contractor, please list the items to take as PPE.

A// Since the area to be visited is not in a construction zone, it will not be necessary to bring or give PPE.

The following questions were during the Site Visit:

Q 2. Is there any ground connection in the tanks?

A// Yes, there is a ground cable connection.

Q 3. What is the preferred position for the truck to discharge fuel?

A// Reverse parking is preferred.

Q 4. What is the tanks adapter's size in order to connect hose to discharge fuel?

A// Male adapter, three inches (3").